



GENERAL NOTES THIS SHEET:

- A. ALL EXISTING LIGHTING, RECEPTACLES, AND AUXILIARY TO REMAIN.
- B. LOAD CENTER (LC-XXX) SHALL BE NAMED PER RESPECTIVE ROOM NUMBER AS FOLLOWS:
ROOM 100 = LC-100 ROOM 200 = LC-200 ROOM 300 = LC-300

⊙ PLAN NOTES THIS SHEET:

1. INSTALL METAL CLAD CABLE FOR CIRCUITS THROUGH FLOORING TO THE CHASE THEN ABOVE THE BATHROOM CEILING TO LOAD CENTER.
2. INSTALL WIRING AND CONDUIT TIGHT AGAINST THE CEILING TO THE LOAD CENTER.
3. 120V ELECTRICAL CONNECTION FOR TWO EYE COOK-TOP. VERIFY EXACT REQUIREMENTS PRIOR TO ROUGH-IN.
4. 120V ELECTRICAL CONNECTION FOR VENT HOOD ABOVE COOK-TOP. VERIFY EXACT REQUIREMENTS AND MOUNTING HEIGHT PRIOR TO ROUGH-IN.
5. 15 AMP, 120V GFI RECEPTACE FOR CABINET MOUNTED MICROWAVE OVEN. VERIFY EXACT MOUNTING HEIGHT PRIOR TO ROUGH-IN.
6. FIRE ALARM SYSTEM CONNECTED PHOTOELECTRIC SMOKE DETECTOR. ALSO SHOWN ON OVERALL PLAN.



TYPICAL BARRIER FREE GUEST ROOM PLAN - ELECTRICAL

SCALE: 1/4" = 1'-0"


TYPICAL GUEST ROOM PLAN - ELECTRICAL

SCALE: 1/4" = 1'-0"


PANEL:		PANEL AMPS:		VOLTAGE:		FLOOR:	
LC-XXX		MAIN TYPE:		120/240, 1 PHASE, 3 WIRE, 60 HZ		FLOOR 1	
(INSERT RM# FOR XXX)		MAIN BREAKER RATING:		10,000		ALL GUEST ROOMS	
TYPE:		SOLID NEUTRAL		CALC. FAULT CURRENT: 4,882 (Worst Case) FEED FROM:		"L" OR "V" PANELS - SEE RERWIRING DIAGRAM	
		GROUND BUS:		100%		BREAKER FEATURES: GF = GROUND FAULT CIRCUIT INTERRUPTER, ST = SHUNT TRIP, TH = TIE HANDLE	
PQL		LOAD		LINE		LOAD	
CKT	BREAKER	TYPE	DESCRIPTION	WIRE SIZE	OUT. LOAD	DESCRIPTION	BREAKER
NO	AMPS/IRF FEATURES						NO
1	200	AF	REFRIGERATOR	#12	300	2100	2
3	200	AF	MICROWAVE	#12	1100	2800	4
5	200	AF	COUNTERTOP OUTLET & KITCHEN HOOD	#12	1500	3000	6
7			PREPARED SPACE		0	0	8
9			PREPARED SPACE		0	0	10
11			PREPARED SPACE		0	0	12
PHASE TOTALS				5100	2800		

SECTION 'A'

SCALE: 1" = 1'-0"




REMOVE EXISTING ALUMINUM MULLION AND GLASS INFILL OPENING WITH INSULATED FRAMED WALL AND 48" X 48" WINDOW. SEE SECTION 'A' - 'A', THIS SHEET.




TYPICAL GUEST ROOM EXTERIOR WALL ELEVATION

SCALE: 1/2" = 1'-0"




TYPICAL BARRIER FREE GUEST ROOM PLAN

SCALE: 1/4" = 1'-0"




TYPICAL GUEST ROOM PLAN

SCALE: 1/4" = 1'-0"



CONSULTING
CONSTRUCTION
ENGINEERING, LLC

1028 2nd Street South
Birmingham, Alabama 35205
Phone: (205) 352-2500 • Web: www.cce-eng.com



SUBURBAN LODGE

5101 MESSER AIRPORT HIGHWAY
BIRMINGHAM, ALABAMA

THIS DRAWING IS THE PROPERTY OF CONSULTING CONSTRUCTION ENGINEERING, LLC. IT IS TO BE USED ONLY FOR THE PROJECT AND SITE SPECIFICALLY IDENTIFIED HEREON. ANY REUSE OR MODIFICATION OF THIS DRAWING WITHOUT THE WRITTEN PERMISSION OF CONSULTING CONSTRUCTION ENGINEERING, LLC IS STRICTLY PROHIBITED.

REVISIONS

NO.	DESCRIPTION	DATE

Date:	
CCE No: 20MCS21	
Drawn: DAG	
Checked: OWP	
File Name: EUP10a9	

UNIT FLOOR PLANS
ELECTRICAL

E-202